

# Innovair™ 200 Series Intelligent Duct Smoke Detectors



## Intelligent Models Available

DH200P (non-relay)  
DH200RP (with relay)

## Product Overview

**Air velocity rating from 500 to 4000 feet per minute (2.54 to 20.32 m/sec.)**

**Patented telescopic sampling tube**

**Easily accessible code wheels**

**Outside mounting tabs**

**Easy and quick mounting to round or rectangular ducts from 1'-12' (0.3-3.7 meters) wide**

**Easy to clean**

**UL recognized field-replaceable power and sensor boards**

**Transparent cover for convenient visual inspection**

**UL 268A listed**

**3-year warranty**

### DH200P (non-relay)

**Has outputs for remote LED display, remote test**

**Incorporates zener diodes to conserve power for communications to other devices**

**Com line power only**

### DH200RP (with relay)



**Powered outputs for remote LED, remote test and sounder**

**Two form "C" auxiliary contacts**

**Can be configured as a relay version or jumpered to mimic a non-relay version**

**Patented cover tamper trouble signal**

**Requires both com line power and one of the following: 24VAC/DC or 120/220VAC for operation**



The System Sensor Innovair™ DH200 Series photoelectric air duct smoke detectors are capable of sensing smoke in air velocities from 500 to 4,000 feet per minute (2.54 to 20.32 m/sec).

The DH200 Series Detector samples air currents passing through a duct and gives dependable performance for shutdown of fans, blowers, and air conditioning systems, preventing the spread of toxic smoke and fire gases through the protected area.

These intelligent sensors communicate and are continuously monitored through the communication line. Detector sensitivity changes caused by dirt, temperature, or humidity are reported to the panel, allowing compensation algorithms to maintain the sensor's set sensitivity. An advance indication at the panel specifies the sensor address, allowing for selected maintenance to be performed as needed.

Remote alarm annunciation can be accomplished by using the RA400Z Remote Annunciator or the RTS451 or RTS451KEY Remote Test Station. Both these devices allow testing of the detector from a remote location.

The Innovair family is designed for simplified installation and easy maintenance. The modular construction allows for easy cleaning and uncomplicated field replacement of the UL recognized power and sensor boards.

**WARNING:** Duct smoke detectors have specific limitations.

### DUCT SMOKE DETECTORS ARE:

NOT a substitute for an open area smoke detector,

NOT a substitute for early warning detection, and

NOT a replacement for a building's regular fire detection system.

Refer to NFPA 72 and 90A for additional duct smoke detector application information.



**Architect/Engineer Specifications**

The duct smoke detector shall be a System Sensor Model DH200P or DH200RP Intelligent Series Duct Smoke Detector to be used with compatible control panels. The duct smoke detector shall be UL listed per UL 268A, Standard for Smoke Detectors for Duct Applications, specifically for use in air handling systems. The detector shall operate in air velocities from 500 to 4000 feet per minute. The detector

shall be an intelligent photoelectronic detector. It shall be capable of local testing via magnetic switch or remote testing from the RTS451 or RTS451KEY Remote Test Station. The duct smoke detector housing shall incorporate an airtight smoke chamber in compliance with UL 268A. The housing shall be capable of mounting to either rectangular or round ducts without adapter brackets. An integral filter system

shall be included to reduce dust and residue effects, thereby reducing maintenance and servicing. Sampling tubes shall be easily installed after the housing is mounted to the duct by passing through the duct housing. Terminal connections shall be of the strip and clamp method suitable for 12-18 AWG wiring.

**DH200P Specifications**

**Voltage Range**

15 to 32 VDC


**Standby Current**

300µA @ 24 VDC (one communication every 5 seconds with LED blink enabled)

**Accessory Current Loads**


Device	Standby	Alarm
RA400Z	0 mA	10 mA Max.
RTS451/RTS451KEY	0 mA	7.5 mA Max.

**Wiring diagram for DH200P Duct Smoke Detector using a UL listed control panel**




**Wiring diagram for DH200P Duct Smoke Detector with optional RA400Z**

(Must break tab on back of RA400Z when used with DH200P.)



**Wiring diagram for DH200P Duct Smoke Detector with RTS451/RTS451KEY**



FOR RTS451, TERMINAL 3 IS NOT USED.  
 (RTS451 DOES NOT HAVE A TERMINAL 6.)  
 FOR RTS451KEY, TERMINALS 3 AND 6 ARE NOT USED.

## DH200RP Specifications

### Current Requirements (using no accessories)

Power supply voltage	20-30 VDC	24 VAC, 50-60HZ	120VAC, 50-60Hz	220/240 VAC, 50-60Hz
Max. standby current	26 mA	65 mA RMS	44 mA RMS	25 mA RMS
Max. alarm current	87 mA	182 mA RMS	52 mA RMS	30 mA RMS
Alarm response time	3 to 17 sec.	3 to 17 sec.	3 to 17 sec.	3 to 17 sec.
Power up time	2 sec.	2 sec.	2 sec.	2 sec.

### Contact Ratings

#### Alarm auxiliary contacts\* (DPDT)

- 10 A @ 30 VDC
- 10 A @ 277 VAC (0.75 power factor)
- 240 VA @ 249 VAC (0.4 power factor)
- 1/8 HP @ 120 VAC
- 1/4 HP @ 240 VAC

#### Supervisory contact (SPST)

- 2.0 A @ 30 VDC (resistive)


\*Minimum switching current for auxiliary contact must be 500 mA DC minimum @ 24 VDC.

### Accessory Current Loads at 24 VDC

Device	Standby	Alarm
PA400	0 mA	15 mA Max.
RA400Z	0 mA	12 mA Max.
RTS451/RTS451KEY	0 mA	10 mA Max.


### Wiring diagram for DH200RP Duct Smoke Detector using a UL listed control panel

NOTE: Jumper J1 shunt must be installed for non-relay applications. J1 shunt must be removed for power supervision.




NOTE: External power of 24V AC/DC or 120/220 VAC must be connected in order to power all remote horn or strobe accessories.

### Wiring diagram for DH200RP Duct Smoke Detector with optional RA400Z




### Wiring diagram for DH200RP Duct Smoke Detector with optional RTS451/RTS451KEY



FOR RTS451, TERMINAL 3 IS NOT USED. (RTS451 DOES NOT HAVE A TERMINAL 6.) FOR RTS451KEY, TERMINALS 3 AND 6 ARE NOT USED.

### Wiring diagram for DH200RP Duct Smoke Detector with optional PA400



## Innovair™ 200 Series Specifications

### Operating Temperature Range

32° to 131°F (0° to 55°C)

### Operating Humidity Range

10% to 93% relative humidity  
(non-condensing)

### Duct Air Velocity

500 - 4000 ft./min. (2.54 - 20.32 m/s)

### Length

14-3/8" (37 cm)

### Width


5-1/2" (14 cm)

### Depth

2-3/4" (7 cm)


## Ordering Information

Part No.	Description	Accessories	Description
DH200P	Innovair™ intelligent photoelectric non-relay duct smoke detector	RTS451	Remote test station (see below)
DH200RP	Innovair™ intelligent photoelectric with relay duct smoke detector	RTS451KEY	Remote test station w/key (see below)
ST-1.5	Metal sampling tube duct widths 1'-2'	RA400Z	Remote LED (see below)
ST-3	Metal sampling tube duct widths 2'-4'	PA400	Mini-Alert™ Sounder (see below)
ST-5	Metal sampling tube duct widths 4'-8'	F36-09-11	Replacement filters
ST-10	Metal sampling tube duct widths 8'-12'	M02-04-00	Test magnet
A5053	Replacement photoelectric sensor board	P48-21-00	End cap for metal sampling tube
A5060	Replacement power board for DH200RP (w/relay)	P48-55-00	End cap for plastic sampling tube
A5067	Replacement power board for DH200P (w/o relay)	S08-39-01	Replacement photo insect screen
		T80-71-00	Replacement plastic sampling tube




### RTS451

Remote Test Station  
(UL S2522)




### RTS451KEY

Remote Test Station with  
Key (UL S2522)



### RA400Z

Remote  
Annunciator  
(UL S2522)



### PA400

Mini-Alert™ Sounder  
(UL S3593)  
Device can not be wired  
directly to DH200P  
(non-relay).

## System Sensor Sales and Service

### System Sensor Headquarters

3825 Ohio Avenue  
St. Charles, IL 60174  
Ph: 800/SENSOR2  
Fx: 630/377-6495  
Documents-on-Demand  
800/736-7672 x3  
www.systemsensor.com

### System Sensor Canada

Ph: 905.812.0767  
Fx: 905.812.0771

### System Sensor Europe

Ph: 44.1403.276500  
Fx: 44.1403.276501

### System Sensor in China

Ph: 86.29.524.6253  
Fx: 86.29.524.6259

### System Sensor in Singapore

Ph: 65.273.2230  
Fx: 65.273.2610

### System Sensor – Far East

Ph: 85.22.191.9003  
Fx: 85.22.736.6580

### System Sensor – Australia

Ph: 613.54.281.142  
Fx: 613.54.281.172

### System Sensor – India

Ph: 91.11.558.2119  
Fx: 91.11.567.6815